

Fire Suppression Design Criteria

May 2017 324 1/2

DATE	
SUBJECT PROPERTY STREET ADDRESS	
PROJECT OR FACILITY NAME	
Water Flow Information See Worksheet on Page 2	
STATIC	PSI
RESIDUAL	PSI
WATER FLOW	GPM
DURATION Length of time water source is capable of providing adequate water during a fire condition.	MINS
SOURCE OF WATER SUPPLY Tank, Lake, Etc.	
SOURCE OF WATER FLOW DATA Person or persons who conducted test.	
DATE AND TIME OF WATER FLOW TEST Water flow test shall have been conducted within the past six months.	
ANTICIPATED WATER DEMAND Minimum water and pressure required to operate this system.	PSI
	GPM
CLASSIFICATION OF HAZARD(S) Light, Ordinary Group 1, 2, 3, Extra Hazard Group 1, 2.	
OCCUPANCY OF BUILDING Mercantile, Restaurant, Office, School, Industrial Plant, etc.	
SPECIFIC TYPES OF SUPPRESSION SYSTEM(S) Wet, Dry, Preaction, Deluge, etc.	
NFPA STANDARD(S) FOLLOWED IN DESIGN 13,14, 22, 24, 231, 231C, etc.	
Ι, ,	AFFIX ENGINEER'S SEAL AND SIGNATURE HERE
verify that the fire suppression design criteria are in accordance with all applicable codes and standards adopted by the Commonwealth and that the water flow information noted above is true and accurate. I further acknowledge that I have reviewed the anticipated water demand for this system and find the actual water flow and pressure adequate to serve this system. It is understood that I will be responsible for the approval of the final shop drawings prior to their submittal to the OMPC.	
ST. ADDRESS	
CITY	
STATE ZIP	

Fire Flow Test Data Sheet

Date Test Conducted:

Static Pressure	Residual Pressure	Pitot Pressure	Flow Table	Hydrant Nozzle	Hydrant	Hydrant Butt	Flow Openings	Remarks
PSI	PSI	PSI	C	Coefficient	#	#	Inches	

INSTRUCTIONS:

- 1. Sketch site showing road(s), building(s), water main and location of test hydrants.
- 2. Record test data in table above.

333 667 1000

4542

15143028

1333


1667

2000

9085

- 3. Plot graph and determine required design data.
- 4. Transpose data to Page 1.

SKETCH OF TEST LOCATION



3333

15142

2333

2667

12113

3000

13627